

## GENERAL NOTES

1. NOT FOR INSTALLATION IN ROADWAYS, DRIVEWAYS, PARKING AREAS OR SIDEWALKS.
2. IF SURFACE IS NOT TO OFFICIAL GRADE AT TIME OF INSTALLATION OF METER, OWNER MUST RAISE OR LOWER PIT WHEN SURFACE IS GRADED.
3. METER SHALL BE SET AT PROPERTY LINE WITHIN PUBLIC R.O.W. OR EASEMENT.
4. NO CONCRETE FLOOR TO BE LAID IN METER PT.
5. METER PIT SHALL BE CONSTRUCTED OF MODIFIED HI-DENSITY POLYETHELENE OR AS SUPPLIED BY THE CITY.
6. ADJUSTMENT RINGS SHALL BE 2", 3", 4" OR 6" IN HEIGHT AND SHALL BE INSERTED BETWEEN THE TWO TOP RINGS.
7. FOR WATER SERVICE LINES 1" AND LARGER: IF THE METER PIT IS NOT INSTALLED WITHIN THE PUBLIC R.O.W. THEN A CURB STOP AND BOX SHALL BE INSTALLED WITHIN THE PUBLIC R.O.W.

(PAGE 2 OF 2)



**CITY of DELTA**  
360 MAIN STREET  
DELTA, CO 81416

SETTINGS FOR  
3/4" & 1" METERS

DATE: DEC. 1998

SHEET W9 OF 24